

Declaration
of Conformity 59581/01

Conformance report 125121

Date 24 March 2011

Replaces : -

Declaration of Conformity

Declaration of conformity to ISO 17484-1

Kiwa Nederland B.V. declares that, based on tests, the HENCO GAS (PVDF) system as certified by Kiwa Nederland B.V. and manufactured by

Henco Industries N.V.

may, on delivery, be relied upon to comply with;
ISO 17484-1 : "Plastics piping systems – Multilayer pipe systems for indoor gas installations with a maximum operating pressure up to and including 5 bar (500 kPa), Part 1: Specifications for systems".

Remarks

The HENCO GAS (PVDF) system is composed of PE-Xc/AL/Pe-Xc pipes and PVDF press fittings and is tested for indoor gas installations with a maximum operating pressure up to and including 5 bar.

The following dimensions are covered under this declaration of conformity:
16x2,0 - 20x2,0 - 26x3,0 - 32x3,0 - 40x3,5 mm.


Marking

- The marking must be in compliance with ISO 17484-1.

Recommendations for customers

Check at the time of delivery whether:

- the products show no visible defects as a result of transport etc.
- the declaration of conformity is valid, as long as the corresponding GASTEC QA Agreement Q10/003 is valid.
- publication of this declaration is allowed and consists of 1 page.



Bouke Meekma
Kiwa

Manufacturer

Henco Industries N.V.
Toekomstlaan 27
B-2200 Herentals
Belgium
Telefoon +32 1421 8703
Telefax +32 1421 8712
e-mail info@henco.be
internet www.henco.be