



AENOR Product Certificate



001/006910

AENOR certifies that the organization

HENCO INDUSTRIES NV

registered office Toekomstlaan, 27 B-2200 Herentals (Bélgica)

supplies **Flooring heating systems**

in compliance with the standards
UNE-EN 1264-1:2022 (EN 1264-1:2021)
UNE-EN 1264-2:2022 (EN 1264-2:2021)
UNE-EN 1264-3:2022 (EN 1264-3:2021)
UNE-EN 1264-4:2022 (EN 1264-4:2021)
UNE-EN 1264-5:2022 (EN 1264-5:2021)

System description Details in annex for more information.

Production site Toekomstlaan, 27 B-2200 Herentals (Bélgica)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 01.64.

This certificate supersedes 001/006910, dated 2022-05-06

First issued on 2019-02-13
Modified on 2023-01-19
Validity 2024-02-13

Rafael GARCÍA MEIRO
Chief Executive Officer



AENOR Product Certificate

001/006910

Annex to Certificate

System description Trademark: HENCO
Type of structure: Type A
Subtype: A2
Type of insulating panel: EPS
Thickness declared the flat part: 30 mm
Thickness declared including molded part: 52 mm
Effective thermal resistance of the panel: 0,75 m²K/W
Panel thermal conductivity: 0,040 W/mK
Type of coating: Mortar with additive ROLIT UFH-ADN10
Thickness of the mortar: 0,045 m
Type of pipe: PEX-c/AL/PEX-c pipes (AENOR cert. 001/006563)
Pipe dimension: 16x2 mm

Pipe distance (mm)	Standard specific thermal output qN (W/m ²)	Standard temperature difference DT(K)	Equivalent thermal transmittance (W/m ² K)	Verification method	Date
100	96,24	16,20	5,96	Experimental	2022-04-06
150	95,07	16,22	5,86	Experimental	2022-12-15
200	87,37	19,96	4,38	Experimental	2021-04-14

First issued on 2019-02-13
Modified on 2023-01-19
Validity 2024-02-13

