

AENOR

AENOR Product Certificate Plastics



001/006910

AENOR certifies that the organization

HENCO INDUSTRIES NV

registered office TOEKOMSTLAAN, 27 B-2200 HERENTALS (Bélgica)

supplies Flooring heating systems

in compliance with the standards
UNE-EN 1264-1:2012 (EN 1264-1:2011)
UNE-EN 1264-2:2009+A1:2013 (EN 1264-2:2008+A1:2012)
UNE-EN 1264-3:2010 (EN 1264-3:2009)
UNE-EN 1264-4:2010 (EN 1264-4:2009)

System description Details in annex for more information.

Production site TOEKOMSTLAAN, 27 B-2200 HERENTALS (Bélgica)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 01.64.

This certificate supersedes 001/006910, dated 2020-09-14

First issued on 2019-02-13
Modified on 2021-04-22
Validity date 2024-02-13

Rafael GARCÍA MEIRO
Chief Executive Officer

AENOR

AENOR Product Certificate Plastics

001/006910

Annex to Certificate

System description Trademark: HENCO
Type of structure: Type A
Type of insulating panel: Expanded polystyrene panel with profile part
Thickness of the flat part of the panel: 33 mm
Thickness of the profile part of the panel: 52 mm
Effective thickness of the panel: 38 mm
Effective thermal resistance of the panel: 0,90 m²K/W
Panel thermal conductivity: 0,040 W/mK
Type of coating: Mortar with additive ADN 10
Thickness of the mortar: 0,045 m
Type of pipe: PEX-c/AL/PEX-c pipes (AENOR cert. 001/006563)
Pipe dimension: 16x2 mm

PIPE DISTANCE (mm)	STANDARD SPECIFIC THERMAL OUTPUT qN (W/m ²)	STANDARD TEMPERATURE DIFFERENCE DT(K)	EQUIVALENT THERMAL TRANSMITTANCE KH (W/m ² K)	VERIFICATION METHOD	DATE
100	98,56	17,08	5,77	Theoric value	2019-02-13
150	94,49	17,98	5,37	Experimental	2019-11-08
200	87,37	19,96	4,38	Experimental	2021-04-14

First issued on 2019-02-13
Modified on 2021-04-22
Validity date 2024-02-13

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com